

Our Ref: HL/M1301036  
Test Report: MA4484/L

23<sup>rd</sup> May 2013

Rich. Klinger Dichtungstechnik GmbH & Co. KG.  
Am Kanal 8-10,  
2352 Gumpoldskirchen,  
Austria

**WATER REGULATIONS ADVISORY SCHEME (WRAS)**  
**MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS 6920-1:2000 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

**FIBRE**

**5075**

Klingersil C-4430 plus. NBR fibre gasket material, manufactured by calendaring, which is red on one side and off-white on the other side. For use with water up to 23°C.  
For use only as a jointing/gasket material having been tested at a reduced surface area to volume ratio.

**APPROVAL NUMBER: 1304522**


**APPROVAL HOLDER: RICH. KLINGER DICHTUNGSTECHNIK GMBH & CO. KG.**

The Scheme reserves the right to review approval. This approval is valid between April 2013 and April 2018.

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: [www.wras.co.uk/directory](http://www.wras.co.uk/directory)

Yours faithfully



Jason Furnival  
Approvals & Enquiries Manager  
Water Regulations Advisory Scheme